


DRM-M-04 Modbus I/O module with 4 relay outputs

DRM-M-04 are relay output modules for Modbus networks. They feature 4 C/O relays with a normally open and normally closed contact. The status of the relays can be controlled by Modbus RTU communication.



Wiring and connections



RJ45 socket	
Supply voltage, 24 VDC	Pin 1
	Pin 2
Modbus RTU communication, signal A	Pin 3
	Pin 4
Modbus RTU communication, signal /B	Pin 5
	Pin 6
Ground, supply voltage	Pin 7
Ground, supply voltage	Pin 8

RJ45 socket



NO1	Normally open contact 1
COM1	Common contact 1
NC1	Normally closed contact 1
NO2	Normally open contact 2
COM2	Common contact 2
NC2	Normally closed contact 2
NO3	Normally open contact 3
COM3	Common contact 3
NC3	Normally closed contact 3
NO4	Normally open contact 4
COM4	Common contact 4
NC4	Normally closed contact 4



- 4 C/O relays with a normally open and normally closed contact
- Modbus RTU communication

.......

.....

- DIN rail mountable
- Firmware updates can be pushed via Modbus RTU communication (integrated bootloader)

	Tecl	hnical specifications	
Supply voltage	24 VDC PoM		
Maximum current consumption	60 mA		
Maximum switching voltage	220 VDC / 250 VAC		
Maximum switching current	5 A (resistive load)		
Protection class	IP30 (EN 60529)		
A 11 1 111	Operating temperature	-20—60 °C	
Ambient conditions	Relative humidity	5-90 % rH, non-condensing	

	Area of use
For indoor use only.	
Control external devices via the relay outputs	

• The Modbus master can adjust the relay status via the Modbus registers

Article codes

DRM-M-04 4 C/O relay outputs

Standards

CE

/B ⁸ m A amm

24 VDC

- Low Voltage Directive 2014/35/EU
- EN 50178:1997 Electronic equipment for use in power installations - EN 60529:1991 Degrees of protection provided by enclosures (IP Code). Amendment AC:1993 to EN 60529
- EMC directive 2014/30/EU:
 EN 61000-6-2:2005 Electromagnetic compatibility (EMC) Part 6-2: Generic standards Immunity for industrial environments. Amendment AC:2005 to EN
- 61000-6-2 EN 61000-6-4:2007 Electromagnetic compatibility (EMC) Part 6-4: Generic standards Emission standard for industrial environments Amendment A1:2011 to EN61000-6-4
- RoHs Directive 2011/65/EU
 - EN IEC 63000:2018 Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances



DRM-M-04 Modbus I/O module with 4 relay outputs



			Packagi
	40	194	
		96	
Article	Packaging	Net weight	Gross weight
Article DRM-M-04			Gross weight 0,098 kg

		GTIN
DRM-M-04	Unit (1 pc.)	05401003018736
DRM-M-04	Box (20 pcs.)	05401003504284

SenteraWeb

NBUS

35

Modbus registers


This product requires application dedicated firmware, which can be downloaded from the Sentera website: Select your application via www.sentera.eu/en/solutions.

First, connect all required products including the Sentera internet gateway. Then connect your installation to www.senteraweb.eu. Click "Link to solution" and enter the solution code to download the selected firmware into the connected devices. After the download there is the possibility to use the installation stand alone or to keep the internet gateway connected.

The parameters of the unit can be monitored / configured through the 3SModbus software platform. You can download it from the following link:

https://www.sentera.eu/en/3SMCenter

For more information about the Modbus registers, please refer to the product Modbus Register Map.



		Settings and indications	
		1 9 9 9 9 9 9 9 9 9 9 9 9 9	
1 - RJ45 socket		Modbus RTU communication and 24 VDC	
2 - Green LED on the left	On	Power on indication	
3 - Green LED on the right	On	Active Modbus RTU communication	
4 - Locking clip	000000	At the bottom of the device; used to lock it to the DIN rail	