



⚠ Consult the fan manufacturer for the correct wiring.
First connect the products, then download the firmware for this solution ID via SenteraWeb. The firmware will be automatically downloaded in the connected device(s).

Sentera products		External products	Parameters settings			
Article codes	Description		Article codes	Parameters	Values	Descriptions
MDACM1 DRPS8-24-40 DIG-M-2 6 x SPRKM-R 6 x ADPT-3RJ-TB	CO and LPG monitoring in small (private) parking with multiple SPRKM-R sensors. Highest value of sensor is taken for driving output of MADCM1 article with EC extraction fan connected.	115 V or 230 V 1ph voltage controllable EC motor	MDACM1	HR15 'Minimum output value' HR16 'Maximum output value' HR20 'Number of slave devices'	0 – 40 % 60 – 100 % 1 – 6	Minimum output voltage, default = 10 % Maximum output voltage, default = 100 % Adjust according to number of SPRKM-R articles in the solution drawing, default = 1